

Project				Sale, Manchester		Job no.		1/21541	
Calcs for						Start page no./Revision		1	
Calcs by		Calcs date		Checked by		Checked date		Approved by	
CN		27/01/2023							

DESIGN RAINFALL

In accordance with the Wallingford Procedure

Tedds calculation version 2.0.01

Design rainfall intensity

Location of catchment area	Manchester
Storm duration	D = 15 min
Return period	Period = 30 yr
Ratio 60 min to 2 day rainfall of 5 yr return period	r = 0.360
5-year return period rainfall of 60 minutes duration	M5_60min = 18.0 mm
Increase of rainfall intensity due to global warming	p _{climate} = 0 %
Factor Z1 (Wallingford procedure)	Z1 = 0.62
Rainfall for 15min storm with 5 year return period	M5_15min _i = Z1 * M5_60min = 11.2 mm
Factor Z2 (Wallingford procedure)	Z2 = 1.50
Rainfall for 15min storm with 30 year return period	M30_15min = Z2 * M5_15min _i = 16.7 mm
Design rainfall intensity	I _{max} = M30_15min / D = 66.9 mm/hr

Maximum surface water runoff

Catchment area	A _{catch} = 2158 m ²
Percentage of area that is impermeable	p = 59 %
Maximum surface water runoff	Q _{max} = A _{catch} * p * I _{max} = 23.8 l/s